

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: _____ 155

Requestor's RFBI No.: 89

Request Date: June 8, 2009

To: **Richard Myren, Project Director**
Project Management Branch
Real Estate Services Division
Phone: 916-708-4124

From (Bidder): **HMH Builders**

e-mail: richard.myren@dgs.ca.gov

Contact: **Chris Morris**

Phone: (916) 388-4825 Fax: (916) 388-9197

e-mail: cmorris@hmh.com

Project Work Order No.: #118141

Project Name: 6th Floor Asbestos Abatement, Renovation, Building Reskin and
Central Utility Plant

Location: 2415 1st Avenue
Sacramento, CA 95818

Drawing Reference: AD2.2 Project Manual Reference: _____

Question: General Note #8: please provide detail and location for the existing angle to remain at windows.

Bidder's Authorized Signature: Chris Morris

Response:

Response Date: June 11, 2009

See edge of slab at window openings for (E) metal angle to curtain wall attachment.

Responded By: **Jacek Lisiewicz**
Title: Senior Project Manager

Signature: _____

[] Check here if additional pages attached
cc:

Page 1 of _1_