

# REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: \_\_\_\_\_ 45

Requestor's RFBI No.: 3

Request Date: June 4, 2009

To: **Richard Myren, Project Director**  
**Project Management Branch**  
**Real Estate Services Division**  
**Phone: 916-708-4124**

From (Bidder): HMH Builders

e-mail: [richard.myren@dgs.ca.gov](mailto:richard.myren@dgs.ca.gov)

Contact: Chris Morris  
Phone: (916) 388-4825 Fax: (916) 388-9197  
e-mail: [cmorris@hmh.com](mailto:cmorris@hmh.com)

Project Work Order No.: #118141

Project Name: 6<sup>th</sup> Floor Asbestos Abatement, Renovation, Building Reskin and  
Central Utility Plant

Location: 2415 1<sup>st</sup> Avenue  
Sacramento, CA 95818

Drawing Reference: A2.7 Project Manual Reference: \_\_\_\_\_

Question: Please clarify if all the Insulated Wall Panels on Lines 3, 13, B and H are existing or new. Sheet A2.7 shows them as existing but Details 1-4 on Sheet A4.15 do not refer to them as existing. Sheet A4.3 shows them as new Panel A. What is Panel A?

Bidder's Authorized Signature: Chris Morris

Response:

Response Date: June 09,2009

Wall panels are new, sheet A2.7 calls out (E) Louvers. Wall panel "A" refers to corrugation.

Sheet has been revised and will be issued in the next addendum.

Responded By: **Jacek Lisiewicz**

Title: Senior Project Manager

Signature: \_\_\_\_\_

[ ] Check here if additional pages attached

Page 1 of \_1\_

cc: