

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: _____ 47

Requestor's RFBI No.: 5

Request Date: June 4, 2009

To: **Richard Myren, Project Director**
Project Management Branch
Real Estate Services Division
Phone: 916-708-4124

From (Bidder): **HMH Builders**

e-mail: richard.myren@dgs.ca.gov

Contact: **Chris Morris**
Phone: (916) 388-4825 Fax: (916) 388-9197
e-mail: cmorris@hmh.com

Project Work Order No.: #118141

Project Name: 6th Floor Asbestos Abatement, Renovation, Building Reskin and
Central Utility Plant

Location: 2415 1st Avenue
Sacramento, CA 95818

Drawing Reference: M2.1 through M2.5 Project Manual Reference: _____

Question: Please clarify if the work in the existing mechanical rooms is limited to the repiping of the of the air handling unit and an added filter bank. The fan coil units appear to be shown as new, but there is no schedule for them.

Bidder's Authorized Signature: _____ Chris Morris _____

Response: _____ Response Date: 6/10/09 _____

The scope of work is as indicated on the drawings via notes shown.

Fan coils as shown are existing.

Responded By: **Brett Fooks**

Title: _____ Signature: _____

Check here if additional pages attached
cc:

Page 1 of 1