

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: _____ 50

Requestor's RFBI No.: 8

Request Date: June 4, 2009

To: **Richard Myren, Project Director**
Project Management Branch
Real Estate Services Division
Phone: 916-708-4124

From (Bidder): HMH Builders

e-mail: richard.myren@dgs.ca.gov

Contact: Chris Morris

Phone: (916) 388-4825 Fax: (916) 388-9197

e-mail: cmorris@hmh.com

Project Work Order No.: #118141

Project Name: 6th Floor Asbestos Abatement, Renovation, Building Reskin and
Central Utility Plant

Location: 2415 1st Avenue
Sacramento, CA 95818

Drawing Reference: A0.00 Project Manual Reference: _____

Question: Please confirm or provide design criteria for the metal stud w/ hard lid tunnel system. What are egress, engineering or fire requirements and can an alternate system, such as a scaffolding system, if enclosed, be used for overhead protection?

Bidder's Authorized Signature: Chris Morris

Response:

Response Date: June 09, 2009

Design criteria as defined in sections: 01 11 00, 01 51 00 and 01 51 16.

Scaffold system not allowed. Fire alarm not required, non combustibile construction, overhead protection required.

Responded By: **Jacek Lisiewicz**

Title: Senior Project Manager _____ Signature: _____

Check here if additional pages attached

Page 1 of _1_

cc: