

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: _____ 57

Requestor's RFBI No.: 15

Request Date: June 4, 2009

To: **Richard Myren, Project Director**
Project Management Branch
Real Estate Services Division
Phone: 916-708-4124

From (Bidder): HMH Builders

e-mail: richard.myren@dgs.ca.gov

Contact: Chris Morris
Phone: (916) 388-4825 Fax: (916) 388-9197
e-mail: cmorris@hmh.com

Project Work Order No.: #118141

Project Name: 6th Floor Asbestos Abatement, Renovation, Building Reskin and
Central Utility Plant

Location: 2415 1st Avenue
Sacramento, CA 95818

Drawing Reference: _____ Project Manual Reference: _____

Question: Please clarify the following questions regarding exterior skin component mockups:

- A) How many different mockups are required?
- B) What exterior skin components, and the size of each, are to be included in each of these mockups?
- C) Are mockups to be stand alone assemblies that are disconnected from the building or are they to be an actual part of the finished product?

Bidder's Authorized Signature: Chris Morris

Response:

Response Date: June 10, 2009

Addendum #1 addressed changes to sections; 0890 50, 08 90 51

The number of mockups is nine (9), location indicated on the drawings.

The type of individual tests will be identified in the next Addenda.

Responded By: **Jacek Lisiewicz**

Title: Senior Project Manager

Signature: _____

[] Check here if additional pages attached
cc:

Page 1 of _1_