

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: _____ 61

Requestor's RFBI No.: 18

Request Date: June 4, 2009

To: **Richard Myren, Project Director**
Project Management Branch
Real Estate Services Division
Phone: 916-708-4124

From (Bidder): HMH Builders

e-mail: richard.myren@dgs.ca.gov

Contact: Chris Morris
Phone: (916) 388-4825 Fax: (916) 388-9197
e-mail: cmorris@hmh.com

Project Work Order No.: #118141

Project Name: 6th Floor Asbestos Abatement, Renovation, Building Reskin and
Central Utility Plant

Location: 2415 1st Avenue
Sacramento, CA 95818

Drawing Reference: A4.15 Project Manual Reference: 01 23 00 - 1

Question: Please clarify the material type and specification section for the roof canopy material indicated as "metal panel system" in Detail 4 of Sheet A4.15 (and for the related Alternate #2).

Bidder's Authorized Signature: Chris Morris

Response:

Response Date: June 12, 2009

Aluminum Composite Wall Panel 07 42 43 16
Additional information in next Addendum.

Responded By: **Jacek Lisiewicz**
Title: Senior Project Manager

Signature: _____

Check here if additional pages attached
cc:

Page 1 of _1_