

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: _____ 62

Requestor's RFBI No.: 19

Request Date: June 4, 2009

To: **Richard Myren, Project Director**
Project Management Branch
Real Estate Services Division
Phone: 916-708-4124

e-mail: richard.myren@dgs.ca.gov

From (Bidder): HMH Builders

Contact: Chris Morris
Phone: (916) 388-4825 Fax: (916) 388-9197
e-mail: cmorris@hmh.com

Project Work Order No.: #118141

Project Name: 6th Floor Asbestos Abatement, Renovation, Building Reskin and
Central Utility Plant

Location: 2415 1st Avenue
Sacramento, CA 95818

Drawing Reference: _____ Project Manual Reference: 07 13 26

Question: Project Manual Book 1 of 2 page 07 13 16 - 1 Section 1.1, items 1 and 2 indicate two (2) locations that self-adhesive elastomeric sheet membrane waterproofing is to be installed. Will this waterproofing also be required at all sheathing behind the following exterior wall panels: composite, insulated metal and phenolic?

Will this material be required at the existing substrate behind the glass curtain walls and clip connections?

Bidder's Authorized Signature: Chris Morris

Response:

Response Date: June 12, 2009

No self adhesive waterproofing membrane under phenolic membrane unless indicated on drawings.

Responded By: **Jacek Lisiewicz**

Title: Senior Project Manager

Signature: _____

[] Check here if additional pages attached
cc:

Page 1 of _1_