

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: _____ 70

Requestor's RFBI No.: 27

Request Date: June 4, 2009

To: **Richard Myren, Project Director**
Project Management Branch
Real Estate Services Division
Phone: 916-708-4124

From (Bidder): **HMH Builders**

e-mail: richard.myren@dgs.ca.gov

Contact: **Chris Morris**
Phone: (916) 388-4825 Fax: (916) 388-9197
e-mail: cmorris@hmh.com

Project Work Order No.: #118141

Project Name: 6th Floor Asbestos Abatement, Renovation, Building Reskin and
Central Utility Plant

Location: 2415 1st Avenue
Sacramento, CA 95818

Drawing Reference: _____ Project Manual Reference: _____

Question: Please clarify the Trespa concealed fasteners system (TS210). Trespa identified a problem with the concealed fastener system during a routine test several months ago where they discovered that their concealed fasteners system(TS210) did not meet all of the requirements for use on high rise construction, which is defined by building over 40'0" in elevation. The result of this is a change to their standard system that requires the use of rock wool insulation in the cavity behind the panels.

Bidder's Authorized Signature: Chris Morris

Response:

Response Date: June 12, 2009

Yes, the fastening detail will be addressed in the future addendum.

Responded By: **Jacek Lisiewicz**
Title: Senior Project Manager

Signature: _____

[] Check here if additional pages attached
cc:

Page 1 of _1_