

# REQUEST FOR BIDDING INTERPRETATION (RFBI)

(E-mail to Project Director)

PMB's RFBI No.: \_\_\_\_\_ 71

Requestor's RFBI No.: 28

Request Date: June 4, 2009

To: **Richard Myren, Project Director**  
**Project Management Branch**  
**Real Estate Services Division**  
**Phone: 916-708-4124**

From (Bidder): **HMH Builders**

e-mail: [richard.myren@dgs.ca.gov](mailto:richard.myren@dgs.ca.gov)

Contact: **Chris Morris**  
**Phone: (916) 388-4825 Fax: (916) 388-9197**  
**e-mail: [cmorris@hmh.com](mailto:cmorris@hmh.com)**

Project Work Order No.: #118141

Project Name: 6<sup>th</sup> Floor Asbestos Abatement, Renovation, Building Reskin and  
Central Utility Plant

Location: 2415 1<sup>st</sup> Avenue  
Sacramento, CA 95818

Drawing Reference: \_\_\_\_\_ Project Manual Reference: \_\_\_\_\_

Question: Please confirm the maximum live and dead loads for the 6<sup>th</sup> floor, 6<sup>th</sup> floor roof, penthouse floor and penthouse roof.

Bidder's Authorized Signature: Chris Morris

Response: \_\_\_\_\_ Response Date: \_\_\_\_\_

Design Live Loads are listed on sheet S0.1 under design criteria for:

Floors (6<sup>th</sup> Floor), Roof (6<sup>th</sup> floor roof and penthouse roof), and Mechanical electrical area (penthouse floor).

Dead loads will not be listed. Construction loads greater than listed Design Live Loads are considered means and methods per General Notes, item 14, S0.1.

Responded By: **Bill Anders, Lionakis, 6/12/09**

Title: \_\_\_\_\_ Signature: \_\_\_\_\_

[ ] Check here if additional pages attached  
cc:

Page 1 of \_\_\_\_